



Teseo has subjected the pipes and fittings of its AP range to a test at a pressure of 60 bar, with the supervision of TÜV Rheinland Industrie Service GmbH. All tested systems were compliant and showed no losses or deformations.



**Resistance test of TESEO "AP" pipes
and fittings at a pressure of**

60 Bar – 870 psi

**Inspection report n° P28115202
Released by TÜV Rheinland**

